



CHINO VALLEY INDEPENDENT FIRE DISTRICT FIRE PROTECTION STANDARD

ILLUMINATED DIRECTORY

STANDARD # 118

REVISED 12/06/1991 PAGES 1

Condominium, apartment complexes, townhouses, and mobile home parks shall have installed at points of entry, an illuminated directory consisting of a plot plan showing private drives, access roads, building locations with unit numbers and addresses, and fire hydrant locations.

Illumination of the directory shall be internally so as to prevent vandalism/damage to the lighting assembly.

The directory shall also include the name of the complex; a reference point on the plot plan indicating the location of the directory; and north direction indicator.

The developer or the property owner shall submit to the Fire Department for review and approval, a detailed plan showing size, materials, method of construction, electrical components and wiring, and location of installation.

The scale shall be 1" = 20 feet.

John Doe Apartments 12345 Street Blvd.

EXAMPLE:

